

Exhibit 6. Transboundary Flow and Spill Event Bacteria Monitoring

Date	Canyon Collector	Flow v. Pool	Category	Spill Amount (gallons)	Parameter	WQO	Result	Units
1/7/2022	Stewart's Drain	Flow	1	942,480	Enterococcus	30 geometric mean (GM)/ 110 statistical threshold value (STV)	2700000	cfu/100ml
1/7/2022	Stewart's Drain	Pool	1	942,480	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/7/2022	Stewart's Drain	Pool	1	942,480	Fecal Coliform	2000 (30-day avg)/ 4000 single sample	1300000	cfu/100ml
1/7/2022	Stewart's Drain	Flow	1	942,480	Fecal Coliform	2000 / 4000	3500000	cfu/100ml
1/8/2022	Stewart's Drain	Flow	1	643,280	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/8/2022	Stewart's Drain	Flow	1	643,280	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
1/8/2022	Stewart's Drain	Pool	1	643,280	Enterococcus	30 GM / 110 STV	3500000	cfu/100ml
1/8/2022	Stewart's Drain	Pool	1	643,280	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
1/9/2022	Stewart's Drain	Flow	1	13,164,800	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/9/2022	Stewart's Drain	Flow	1	13,164,800	Fecal Coliform	2000 / 4000	2700000	cfu/100ml
1/9/2022	Stewart's Drain	Pool	1	13,164,800	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/9/2022	Stewart's Drain	Pool	1	13,164,800	Fecal Coliform	2000 / 4000	1500000	cfu/100ml
1/10/2022	Stewart's Drain	Flow	1	17,054,400	Enterococcus	30 GM / 110 STV	2700000	cfu/100ml
1/10/2022	Stewart's Drain	Flow	1	17,054,400	Fecal Coliform	2000 / 4000	2200000	cfu/100ml
1/10/2022	Stewart's Drain	Pool	1	17,054,400	Fecal Coliform	2000 / 4000	1900000	cfu/100ml
1/10/2022	Stewart's Drain	Pool	1	17,054,400	Enterococcus	30 GM / 110 STV	1100000	cfu/100ml
1/11/2022	Stewart's Drain	Flow	1	8,213,040	Enterococcus	30 GM / 110 STV	2700000	cfu/100ml
1/11/2022	Stewart's Drain	Flow	1	8,213,040	Fecal Coliform	2000 / 4000	2200000	cfu/100ml
1/11/2022	Stewart's Drain	Pool	1	8,213,040	Enterococcus	30 GM / 110 STV	1100000	cfu/100ml
1/11/2022	Stewart's Drain	Pool	1	8,213,040	Fecal Coliform	2000 / 4000	1900000	cfu/100ml
1/12/2022	Stewart's Drain	Flow	1	2,677,840	Enterococcus	30 GM / 110 STV	1300000	cfu/100ml
1/12/2022	Stewart's Drain	Flow	1	2,677,840	Fecal Coliform	2000 / 4000	800000	cfu/100ml
1/12/2022	Stewart's Drain	Pool	1	2,677,840	Enterococcus	30 GM / 110 STV	1300000	cfu/100ml
1/12/2022	Stewart's Drain	Pool	1	2,677,840	Fecal Coliform	2000 / 4000	2200000	cfu/100ml
1/13/2022	Stewart's Drain	Pool	1	2,244,000	Enterococcus	30 GM / 110 STV	900000	cfu/100ml
1/13/2022	Stewart's Drain	Pool	1	2,244,000	Fecal Coliform	2000 / 4000	1100000	cfu/100ml
1/13/2022	Stewart's Drain	Flow	1	2,244,000	Enterococcus	30 GM / 110 STV	2200000	cfu/100ml
1/13/2022	Stewart's Drain	Flow	1	2,244,000	Fecal Coliform	2000 / 4000	3300000	cfu/100ml
1/14/2022	Stewart's Drain	Flow	1	1,196,800	Enterococcus	30 GM / 110 STV	2500000	cfu/100ml
1/14/2022	Stewart's Drain	Flow	1	1,196,800	Fecal Coliform	2000 / 4000	1300000	cfu/100ml
1/14/2022	Stewart's Drain	Pool	1	1,196,800	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/14/2022	Stewart's Drain	Pool	1	1,196,800	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
1/15/2022	Stewart's Drain	Flow	1	718,080	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/15/2022	Stewart's Drain	Flow	1	718,080	Fecal Coliform	2000 / 4000	3300000	cfu/100ml
1/15/2022	Stewart's Drain	Pool	1	718,080	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
1/15/2022	Stewart's Drain	Pool	1	718,080	Fecal Coliform	2000 / 4000	700000	cfu/100ml
1/19/2022	Stewart's Drain	Flow	1	44,880	Enterococcus	30 GM / 110 STV	1700000	cfu/100ml
1/19/2022	Stewart's Drain	Flow	1	44,880	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
1/19/2022	Stewart's Drain	Pool	1	44,880	Enterococcus	30 GM / 110 STV	3300000	cfu/100ml
1/19/2022	Stewart's Drain	Pool	1	44,880	Fecal Coliform	2000 / 4000	2700000	cfu/100ml
1/30/2022	Stewart's Drain	Flow	1	97,240	Enterococcus	30 GM / 110 STV	2200000	cfu/100ml
1/30/2022	Stewart's Drain	Flow	1	97,240	Fecal Coliform	2000 / 4000	900000	cfu/100ml
1/30/2022	Stewart's Drain	Pool	1	97,240	Enterococcus	30 GM / 110 STV	1700000	cfu/100ml
1/30/2022	Stewart's Drain	Pool	1	97,240	Fecal Coliform	2000 / 4000	1700000	cfu/100ml
1/15/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	1400000	cfu/100ml
1/15/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	1800000	cfu/100ml
1/17/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2400000	cfu/100ml
1/17/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	2800000	cfu/100ml
1/18/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2700000	cfu/100ml
1/18/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	1900000	cfu/100ml
1/21/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	1500000	cfu/100ml
1/21/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	500000	cfu/100ml
2/20/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2800000	cfu/100ml
2/20/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
2/21/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	5000000	cfu/100ml
2/21/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	3500000	cfu/100ml
2/26/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	110000	cfu/100ml
2/26/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	160000	cfu/100ml
4/15/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	3500000	cfu/100ml
4/15/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	2200000	cfu/100ml
4/17/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	3000000	cfu/100ml
4/17/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
4/18/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	1900000	cfu/100ml
4/18/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
4/19/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	1100000	cfu/100ml
4/19/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	3500000	cfu/100ml
4/20/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	1500000	cfu/100ml
4/20/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	5000000	cfu/100ml
4/24/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2700000	cfu/100ml
4/24/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	1600000	cfu/100ml
4/25/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2500000	cfu/100ml
4/25/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	9000000	cfu/100ml
4/29/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	2400000	cfu/100ml
4/29/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	700000	cfu/100ml

Exhibit 6. Transboundary Flow and Spill Event Bacteria Monitoring

Date	Canyon Collector	Flow v. Pool	Category	Spill Amount (gallons)	Parameter	WQO	Result	Units
5/19/2021	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>5000000</b>	cfu/100ml
5/19/2021	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>5000000</b>	cfu/100ml
3/16/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>&gt;1600000</b>	cfu/100ml
3/16/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>&gt;1600000</b>	cfu/100ml
5/3/2020	Canyon Del Sol	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>7500000</b>	cfu/100ml
5/3/2020	Canyon Del Sol	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>1700000</b>	cfu/100ml
9/5/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>700000</b>	cfu/100ml
9/5/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>3500000</b>	cfu/100ml
11/23/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>2700000</b>	cfu/100ml
11/23/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>3200000</b>	cfu/100ml
11/26/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>950000</b>	cfu/100ml
11/26/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>1400000</b>	cfu/100ml
11/10/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>2000000</b>	cfu/100ml
11/10/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>1700000</b>	cfu/100ml
11/16/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>800000</b>	cfu/100ml
11/16/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>1800000</b>	cfu/100ml
12/19/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>2200000</b>	cfu/100ml
12/19/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>1100000</b>	cfu/100ml
12/21/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>1800000</b>	cfu/100ml
12/21/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>950000</b>	cfu/100ml
12/26/2020	Stewart's Drain	Unkown	Unkown	Unkown	Enterococcus	30 GM / 110 STV	<b>2200000</b>	cfu/100ml
12/26/2020	Stewart's Drain	Unkown	Unkown	Unkown	Fecal Coliform	2000 / 4000	<b>2100000</b>	cfu/100ml